OVE Austrian Electrotechnical Association
Eschenbachgasse 9 | 1010 Wien | Austria
ZVR: 327279890 | www.ove.at

OVE Certification
Kahlenberger Str. 2A | 1190 Wien | Austria
T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark

Certificate No.: **43-214-08**

Valid from: 2026 02 17
until: 2028 02 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: **3704-1856/22**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Wien, 2026 01 21

Dipl.-Ing. T. Neumayer

Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
ÖVE/ÖNORM EN 60309-4:2012-12-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
OVE EN IEC 60309-4:2023-04-01
IEC 60309-1:2021
IEC 60309-2:2021
IEC 60309-4:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for industrial purposes

Type designation: *Rating:*	***Trademark:***
7523 Rated supply current: 32 A 2P+E IP44 or IP44/IP54 Screw terminals with switch see typelist	PCE / ELCEE / SIROX / METECEE
7623 Rated supply current: 32 A 2P+E IP44 or IP44/IP54 Screw terminals with switch and DIN-rail see typelist	PCE / ELCEE / SIROX / METECEE

7823
Rated supply current: 32 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75232
Rated supply current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76232
Rated supply current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78232
Rated supply current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7524
Rated supply current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7624
Rated supply current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

7824
Rated supply current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75242
Rated supply current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76242
Rated supply current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78242
Rated supply current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7525
Rated supply current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7625
Rated supply current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

7825
Rated supply current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75252
Rated supply current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76252
Rated supply current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78252
Rated supply current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

Type code

75	2	3	2	-	6	*	*	*

Switch	
blank	ML0 (4-poles 3h only available with ML1)
ml1	ML1

Contacts	
blank	Nickel plated contacts
b	Uncoated contacts

Colour	
blank	Indicating colour
xs	Midnight-series
*	Reserved for additional colours

Clock position earthing contact	
1	1 h
3	3 h (not available for series 78)
4	4 h
5	5 h (not available for series 78)
6	6 h
7	7 h (not available for series 78)
9	9 h
11	11 h (not available for series 78)
12	12 h

Customer type	
-	Trademark PCE

Degree of protection	
blank	IP44 or IP44/IP54
2	IP67 or IP66/IP67

Poles	
3	3-poles
4	4-poles
5	5-poles

Rated current	
2	32 A

Ground type	
75	With switch
76	With switch and DIN-rail
78	With switch and fuse (Neozed)

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
7523 7623 7823*) 75232 76232 78232*)	32	1	Other ratings	Other ratings	690 / 415*)
		4	100 – 130	50 and 60	690 / 415*)
		6	200 – 250	50 and 60	690 / 415*)
		9	380 – 415	50 and 60	690 / 415*)
		12	Supply from an isolating transformer	50 and 60	690 / 415*)
7524 7624 7824*) 75242 76242 78242*)	32	1	Other ratings	Other ratings	690 / 415*)
		3**)	380 440	50 60	690
		4	100 – 130	50 and 60	690 / 415*)
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690 / 415*)
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690 / 415*)
		11	440 – 460	60	690
		12	Supply from an isolating transformer	50 and 60	690 / 415*)
7525 7625 7825*) 75252 76252 78252*)	32	1	Other ratings	Other ratings	690 / 415*)
		3	220/380 250/440	50 60	690
		4	57/100 – 75/130	50 and 60	690 / 415*)
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	690 / 415*)
		7	277/480 – 288/500	50 and 60	690
		9	120/208 – 144/250	50 and 60	690 / 415*)
		11	250/440 – 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690 / 415*)

*) Insulating voltage 415 V for Series 78… with fuses (Neozed)

**) Only available with switch ML1