OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

OVE Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-132-15 Valid from: 2024 04 16

until: 2025 07 09

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

PC Electric Ges.m.b.H. Certificate holder:

Diesseits 145

4973 St. Martin im Innkreis

Austria

Product: Two-pole plug with side earthing contacts or dual earthing system

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 30145c, TGM-VA EE 37978, **TGM-VA EE 37978A**

Österreichischer Verband für Elektrotechnik

Head of OVE Certification

Digitally signed by T. Neumayer Email=t_neumayer@ove.at

ipl.-Ing. T. Neumayer

Wien, 2024 02 14





Certificate No.: 43-132-15

Date: 2024 02 14 Page 2 of 3

Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Factory location(s):

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01 DIN VDE 0620-2-1:2016-01

Product: Two-pole plug with side earthing contacts or dual earthing system

Type designation: Rating:	Trademark:
05 Rated voltage: AC 250 V Rated current: 16 A IP 54 see typecode	PCE / ELCEE
056 Rated voltage: AC 250 V Rated current: 16 A IP 44 see typecode	PCE / ELCEE
058 Rated voltage: AC 250 V Rated current: 16 A IP 44 see typecode	PCE / ELCEE







Certificate No.: 43-132-15

Date: 2024 02 14 Page 3 of 3

Typecode

)5	6	1	1		-	s	r	1		
				·				_	0.1	1
										ur hexagonal ring (only Types 051* and 052*)
									r he	red
										yellow black
									S	
									o b	orange Blue
									hb	lightblue
									u	green RAL 6031 F9
									hu	fluorescent green
									su	siemensgreen
									g	grrey
									dg	darkgrey
									W	white
									a	anthracite
									*	reserved for different colours
									Color	ur housing part
						L			s	black
									e	yellow
									r	red
									0	orange
									b	blue
									u	green
									g	grey
									a	anthracite
									*	reserved for different colours
									Costi	umer type
									-	PCE
										1 -
									Conta	act carrier
			_							PA6 lightgrey (internal cord anchorage)
									1	black (external cord anchorage)
									2	TPE (anthracite)
									3	PA6 black (internal cord anchorage)
									Stand	lardsheet
		1							1	S.S. IV (with side earthing contacts)
									2	S.S.VII (Two-pole plug)
									Basic	tyne
	<u> </u>								blank	
									6	with external cord anchorage (IP44)
									8	angled plug (IP44)
										Landioa biad (ii 44)
									Plug	

OVE Certification

