#### **OVE Austrian Electrotechnical Association**

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

#### **OVE Certification**

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 4

# **ÖVE-CERTIFICATE**

including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-158-11 Valid from: 2023 04 27

until: 2025 04 27

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

PC Electric Ges.m.b.H. Company:

Diesseits 145

4973 St. Martin im Innkreis

Austria

Product: Plug for industrial purposes

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 35785

Österreichischer Verband für Elektrotechnik


Head of OVE Certification

Digitally signed by T. Neumayer Email=t neumayer@ove.at Digitally signed by T. Neumayer

Dipl.-Ing. T. Neumayer

Wien, 2023 05 12









Certificate No.: 43-158-11

Date: 2023 05 12 Page 2 of 4

#### Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

## **Factory location(s):**

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

### Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01 ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Plug for industrial purposes** 

Type designation: Trademark: Rating:

072 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 without minor key

092 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 with minor key

073 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 without minor key







Certificate No.: 43-158-11

Date: 2023 05 12

Page 3 of 4

093 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 with minor key

0722 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 without minor key

0922 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 with minor key

0732 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 without minor key

0932 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 with minor key







Certificate No.: 43-158-11

Date: 2023 05 12 Page 4 of 4

# Typelist

Туре	Poles	Position minor key [h]	Rated operating- voltage [V]	Frequency [Hz]	Minor keyway
072		-	20-25	50 and 60	without
092	2	12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
073		-	20-25	50 and 60	without
093	3	12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
0722		-	20-25	50 and 60	without
0922	2	12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
0732	3	-	20-25	50 and 60	without
0932		12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	



