#### **OVE Austrian Electrotechnical Association**

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

#### **OVE Certification**

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 4

# **ÖVE-CERTIFICATE**

including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-160-11 Valid from: 2023 04 27

until: 2025 04 27

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

PC Electric Ges.m.b.H. Company:

Diesseits 145

4973 St. Martin im Innkreis

Austria

Product: **Connector for industrial purposes** 

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 37982, 35798

Österreichischer Verband für Elektrotechnik

Head of OVE Certification


Digitally signed by T. Neumayer Email=t neumayer@ove.at Digitally signed by T. Neumayer

Dipl.-Ing. T. Neumayer



Wien, 2023 05 12

**OVE Certification** 







Certificate No.: 43-160-11 Date: 2023 05 12

Page 2 of 4

#### Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

### Factory location(s):

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

#### Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01 ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Tradomark.

## **Product: Connector for industrial purposes**

Rating:	тааетагк:
272 Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 without minor keyway	PCE / ELCEE / METECEE
292 Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 with minor keyway	PCE / ELCEE / METECEE
273 Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54	PCE / ELCEE / METECEE



without minor keyway

Type designation:





Certificate No.: 43-160-11

Date: 2023 05 12

Page 3 of 4

293 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP44 or IP44/IP54 with minor keyway

2722 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 without minor keyway

2922 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 with minor keyway

2732 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 without minor keyway

2932 PCE / ELCEE / METECEE

Rated current: 32 A Insulation voltage: 50 V IP67 or IP66/IP67 with minor keyway





Certificate No.: 43-160-11

Date: 2023 05 12 Page 4 of 4

# **Typelist**

Туре	Poles	Position minor key [h]	Rated operating- voltage [V]	Frequency [Hz]	Minor keyway
272	272	-	20-25	50 and 60	without
292		12	40-50	50 and 60	with
	2	4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
273		-	20-25	50 and 60	without
		12	40-50	50 and 60	with
293		4	20-25 and 40-50	100-200	
	3	2		300	
		3		400	
		11		>400-500	
		10		DC	
2722	2	-	20-25	50 and 60	without
		12	40-50	50 and 60	with
2922		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
2732		-	20-25	50 and 60	without
		12	40-50	50 and 60	with
2932		4	20-25 and 40-50	100-200	
	3	2		300	
		3		400	
		11		>400-500	
		10		DC	



