



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-171-11**

Valid from: 2023 04 19
until: 2025 04 19

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Plug for industrial purposes with switch or integral overcurrent protection**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 36086**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2023 03 06

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Plug for industrial purposes with switch or integral overcurrent protection

Type designation:

Rating:

Trademark:

Serien 53...

Rated operating voltage: 50-690 V
Insulation voltage: AC 450/500/690 V
IP 44 or IP 44/IP 54
see typecode


PCE / ELCEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode

53



clock position

1	-	1h
2	-	2h
3	-	3h
4	-	4h
5	-	5h
blank	-	6h
7	-	7h
9	-	9h
10	-	10h
11	-	11h
12	-	12h

operation display / rotation field check

blank	-	without
1	-	operation display
3	-	rotation field check

switch / setting range

530	-	ON/OFF ML0
610	-	reversing switch K&N CA10
625	-	reversing switch K&N CA25
001	-	MS 0,10-0,16A
002	-	MS 0,16-0,25A
004	-	MS 0,25-0,40A
006	-	MS 0,40-0,63A
010	-	MS 0,63-1,0A
016	-	MS 1,0-1,6A
025	-	MS 1,6-2,5A
040	-	MS 2,5-4,0A
063	-	MS 4,0-6,3A
100	-	MS 6,3-10A
160	-	MS 10-16A
200	-	MS 16-20A
250	-	MS 20-25A
320	-	MS 25-32A
400	-	MS 25-40A
***	-	

Poles

4	-	4pole
5	-	5pole

rated current

1	-	16A
2	-	32A

plug / phase inverter

0	-	Plug
7	-	Phase inverter

ground type

53	-	rotary switch with holder
----	---	---------------------------

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Typelist

Type	Poles	Rated current [A]	Clock position [h]	Rated operating voltage V [V]	Frequency [Hz]
53...	4	16 or 32	1	Other ratings	Other ratings
			2*	> 50	> 300 – 500
			3	380, 440	50, 60
			4	100 – 130	50 and 60
			5	600 – 690	50 and 60
			6	380 – 415	50 and 60
			7	480 – 500	50 and 60
			9	200 – 250	50 and 60
			10*	> 50	> 100 – 300
			11	440 – 460	60
			12	Supply from an isolating transformer	50 and 60
53...	5	16 or 32	1	Other ratings	Other ratings
			2*	> 50	> 300 – 500
			3	220/380, 250/440	50, 60
			4	57/100 – 75/130	50 and 60
			5	347/600 – 400/690	50 and 60
			6	200/346 – 240/415	50 and 60
			7	277/480 – 288/500	50 and 60
			9	200/208 – 144/250	50 and 60
			10*	> 50	100 – 300
			11	250/440 – 265/460	60
			12	Supply from an isolating transformer	50 and 60

*only with switch PKZM0

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.