



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-186-09**

Valid from: 2023 04 19  
until: 2025 04 19

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Socket outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 36041**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2023 03 06



## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Socket outlets for industrial purposes**

**Type designation:**

**Rating:**

**Trademark:**

**843**

Rated current: 16 A  
Insulation Voltage: 690 V  
2P+E  
IP 44 or IP 44/IP 54

PCE / ELCEE

**844**

Rated current: 16 A  
Insulation Voltage: 690 V  
3P+E  
IP 44 or IP 44/IP 54

PCE / ELCEE

**845**

Rated current: 16 A  
Insulation Voltage: 690 V  
3P+N+E  
IP 44 or IP 44/IP 54

PCE / ELCEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**863** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
2P+E  
IP 44 or IP 44/IP 54

**864** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
3P+E  
IP 44 or IP 44/IP 54

**865** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
3P+N+E  
IP 44 or IP 44/IP 54

**883** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
2P+E  
IP 44 or IP 44/IP 54

**884** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
3P+E  
IP 44 or IP 44/IP 54

**885** PCE / ELCEE  
Rated current: 16 A  
Insulation Voltage: 690 V  
3P+N+E  
IP 44 or IP 44/IP 54

**see typecode and typelist**

---

## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

8

8	<p><b>Contacts</b> blank - normal contacts</p> <p><b>Colour</b> blank - white w - pearlwhite g - grey</p> <p><b>Position of earthing contact</b> 1, 2, 3, 4, 5, 6, 7, 9, 10, 11, 12</p> <p><b>Customer type</b> PCE</p> <p><b>Poles</b> 3 - 3pole 4 - 4pole 5 - 5pole</p> <p><b>Construction</b> 4 - 16A Standard (without body housing or box) 6 - 16A surface socket 8 - 16A flush socket</p> <p><b>Series</b> 8 - Design Socket</p>
---	--

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



## Typelist

Type	Rated current [A]	Position of earthing contact [h]	Rated operating voltage [V]	Frequency [Hz]
843, 863, 883	16	1	Other ratings	Other ratings
		2	> 50	> 300 – 500
		3	> 50 – 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		9	380 – 415	50 and 60
		10	> 50	> 100 – 300
	12	Supply from an isolating transformer	50 and 60	
844, 864, 884	16	1	Other ratings	Other ratings
		2	> 50	> 300 – 500
		3	380, 440	50, 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 – 500	50 and 60
		9	200 – 250	50 and 60
		10	> 50	100 – 300
		11	440 – 460	60
			12	Supply from an isolating transformer
845, 865, 885	16	1	Other ratings	Other ratings
		2	> 50	> 300 – 500
		3	220/380, 250/440	50, 60
		4	57/100 – 75/130	50 and 60
		5	347/600 – 400/690	50 and 60
		6	200/346 – 240/415	50 and 60
		7	277/480 – 288/500	50 and 60
		9	120/208 – 144/250	50 and 60
		10	> 50	100 – 300
		11	250/440 – 265/460	60
			12	Supply from an isolating transformer

### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.