



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-230-03**

Valid from: 2022 06 09
until: 2024 06 09

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Socket outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37022, TGM-VA EE 36439**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 04 07



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Socket outlets for industrial purposes

Type designation:

Rating:

Trademark:

127

Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP44 or IP44/IP54

PCE / ELCEE

327

Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP44 or IP44/IP54

PCE / ELCEE

927

Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP44 or IP44/IP54

PCE / ELCEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

1272

Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP67 or IP66/IP67

PCE / ELCEE

3272

Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP67 or IP66/IP67

PCE / ELCEE

9272


Rated current: 32 A
Insulation Voltage: 500 V
6P+E (not standardized)
IP67 or IP66/IP67

PCE / ELCEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode



Contacts

v - Nickel plated contacts

Colour

blank - Identification colour

x - Special design

* - Reserved for additional colours

Clock position of earthing contact

1, 2, 3, 4, 6, 7, 9, 10, 11, 12

Customer type

- PCE

Degree of protection

leer - IP44 or IP44/IP54

2 - IP67 or IP66/IP67

Poles

7 - 7-poles

Rated current

2 - 32A

Basic type

1 - Wall mounted socket outlet

3 - Flanged socket outlet

9 - Wall mounted socket outlet (to loop through)

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current [A]	Earthing contact Position [h]	Degree of protection	Rated operating voltage [V]	Frequency [Hz]			
127 327 927	32	1	IP44 or IP44/IP54	Other ratings	Other ratings			
		2		> 50	> 300 - 500			
		3		380 440	50 60			
		4		100 - 130	50 and 60			
		6		380 - 415	50 and 60			
		7		480 - 500	50 and 60			
		9		200 - 250	50 and 60			
		10		> 50	> 100 - 300			
		11		440 - 460	60			
		12		Supply from an isolating transformer	50 and 60			
		1272 3272 9272		32	1	IP67 or IP66/IP67	Other ratings	Other ratings
					2		> 50	> 300 - 500
3	380 440		50 60					
4	100 - 130		50 and 60					
5	600 - 690		50 and 60					
6	380 - 415		50 and 60					
7	480 - 500		50 and 60					
9	200 - 250		50 and 60					
10	> 50		> 100 - 300					
11	440 - 460		60					
12	Supply from an isolating transformer		50 and 60					

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.