OVE Austrian Electrotechnical Association Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

OVE Certification Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 5



including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-244-03

Valid from: 2023 11 07 until: 2025 07 09

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.** Diesseits 145 4973 St. Martin im Innkreis Austria

Product: Socket-outlets for appliances

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 37134, TGM-VA EE 37135

Österreichischer Verband für Elektrotechnik Head of OVE Certification

Digitally signed by T. Neumayer T. Nean CEmail=t.neumayer@ove.at

Wien, 2023 10 19

OVE Certification

Dipl.-Ing. T. Neumayer





Certificate No.: 43-244-03 Date: 2023 10 19 Page 2 of 5

Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Factory location(s):

OVE Certification

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01 ÖVE/ÖNORM E 8684-2-2:2010-03-01 (only for types without sealing bulge) Beschluss IS 248 (only for types with sealing bulge)

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Socket-outlets for appliances

Type designation: Rating:	Trademark:
105 Rated voltage: AC 250 V Rated current: 16 A IP54, screw terminals without sealing bulge for fixed application	PCE / ELCEE / METECEE
105w Rated voltage: AC 250 V Rated current: 16 A IP54, screw terminals with sealing bulge for portable application	PCE / ELCEE / METECEE





Certificate No.: 43-244-03 Date: 2023 10 19 Page 3 of 5

PCE / ELCEE / METECEE

109... Rated voltage: AC 250 V Rated current: 16 A IP54, screw terminals without sealing bulge for fixed application

109...w Rated voltage: AC 250 V Rated current: 16 A IP54, screw terminals with sealing bulge for portable application

see typecode

PCE / ELCEE / METECEE


OVE Certification





Certificate No.: 43-244-03 Date: 2023 10 19 Page 4 of 5

Typecode for series 105 (two-part construction):



8 - 75x75




OVE Certification



Certificate No.: 43-244-03 Date: 2023 10 19 Page 5 of 5

Typecode for series 109 (two-part construction):



OVE Certification

