



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-151-17**

Valid from: 2024 02 25
until: 2026 02 25

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Portable socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3722-1861/23**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2024 01 08



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Portable socket-outlets for industrial purposes

Type designation:

Rating:

Trademark:

2335

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2336

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2345

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

2346

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2355

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2356

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

233

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

234

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

235

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

23351

Rated current: 63 A
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

23361

Rated current: 63 A
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

23451

Rated current: 63 A
3P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

23461

Rated current: 63 A

3P+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

23551

Rated current: 63 A

3P+N+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

23561

Rated current: 63 A

3P+N+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

2331

Rated current: 63 A

2P+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

2341

Rated current: 63 A

3P+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

2351

Rated current: 63 A

3P+N+PE

IP 44

see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

2	3	5	5	1	-	6	cq	*	v	m
---	---	---	---	---	---	---	----	---	---	---

Lid axis	
blank	made of PC/ABS
m	made of brass (nickel-plated)

Contacts	
blank	uncoated contacts
v	nickel plated contacts

Colour	
blank	standard type
*	reserved for additional colours

Housing	
blank	Design 1
cq	Design 2

Clock position earthing contact	
1	1 h
2	2 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h
8	8 h (not available in 4- and 5-poles)
9	9 h
10	10 h
11	11 h
12	12 h

Customer type	
-	Trademark PCE

Degree of protection	
blank	IP67 or IP66/IP67
1	IP44

Pilot contact	
blank	without pilot contact
5	with pilot contact
6	with PCS system

Poles	
3	3-poles
4	4-poles
5	5-poles

Rated current	
3	63A

Ground type	
2	portable socket-outlet

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
233 2335 2336*) 2331 23351 23361*)	63	1	Other ratings	Other ratings	500*), 690
		2	>50	>300 - 500	500*), 690
		3	>50 – 250	DC	500*), 690
		4	100 – 130	50 and 60	500*), 690
		6	200 – 250	50 and 60	500*), 690
		7	480 – 500	50 and 60	500*), 690
		8**)	>250	DC	500*), 690
		9	380 – 415	50 and 60	500*), 690
		10	>50	>100 - 300	500*), 690
		12	Supply from an isolating transformer	50 and 60	500*), 690
234 2345 2346*) 2341 23451 23461*)	63	1	Other ratings	Other ratings	500*), 690
		2	>50	>300 - 500	500*), 690
		3	380 440	50 60	500*), 690
		4	100 – 130	50 and 60	500*), 690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	500*), 690
		7	480 - 500	50 and 60	500*), 690
		9	200 – 250	50 and 60	500*), 690
		10	>50	>100 - 300	500*), 690
		11	440 – 460	60	500*), 690
		12	Supply from an isolating transformer	50 and 60	500*), 690
		235 2355 2356*) 2351 23551 23561*)	63	1	Other ratings
2	>50			>300 - 500	500*), 690
3	220/380 250/440			50 60	500*), 690
4	57/100 – 75/130			50 and 60	500*), 690
5	347/600 – 400/690			50 and 60	690
6	200/346 – 240/415			50 and 60	500*), 690
7	277/480 – 288/500			50 and 60	500*), 690
9	120/208 – 144/250			50 and 60	500*), 690
10	>50			>100 - 300	500*), 690
11	250/440 – 265/460			60	500*), 690
12	Supply from an isolating transformer			50 and 60	500*), 690

*) Types 2336, 23361, 2346, 23461, 2356, 23561 with insulation voltage 500 V and with add. marking:
"Only for use with electrical interlock"

***) Earthing contact position 8h > 250V DC only for types 2335, 23351, 2336, 23361 with add marking:
"Only for use with electrical interlock"

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.