



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-176-10**

Valid from: 2023 02 01
until: 2025 02 01

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for fixed mounting**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 35769**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2023 02 09



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

PCE Polska Sp.z.o.o.
ul Podwalna 8A
58-200 Dzierzoniow
Poland

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01

ÖVE/ÖNORM EN 60309-2:2013-03-01

ÖVE/ÖNORM EN 60309-4:2012-12-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for fixed mounting

Type designation:

Trademark:

Rating:

960623..

PCE / ELCEE

Rated current: 32 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlet of Type 1050, 105 or 109

960624..

PCE / ELCEE

Rated current: 32 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlet of Type 1050, 105 or 109

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

960625..

PCE / ELCEE

Rated current: 32 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlet of Type 1050, 105 or 109

960723..

PCE / ELCEE

Rated current: 32 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlet of Type 20351, 20352, 30351 or 30352

960724..

PCE / ELCEE

Rated current: 32 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlet of Type 20351, 20352, 30351 or 30352

960725..

PCE / ELCEE


Rated current: 32 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlet of Type 20351, 20352, 30351 or 30352

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode

960 • 2 • • • • • - • •



Special design

blank....standard design

*reserved for additional versions (shutter, colour, etc.)

Clock position earthing contact

-11h

-33h

-44h

-55h

blank....6h

-77h

-99h

-1111h

-1212h

Switch

blank....ON/OFF Switch

1reversing switch

Number of socket-outlet for household

blank....without socket-outlet for household

1one socket-outlet for household

2two socket-outlet for household

optionally socket outlet for household

50without socket-outlet for household

5socket-outlet for household type 1050 (IP44),
20351-8* (IP67)

*reserved for additional versions

Poles

3socket-outlet type 423 (IP44), 4232 (IP67)

4socket-outlet type 424 (IP44), 4242 (IP67)

5socket-outlet type 425 (IP44), 4252 (IP67)

Rated current

232A

Degree of protection

6IP44 or IP44/IP54

7IP67 or IP66/IP67

Ground type

960switched socket-outlet

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Poles	Clock position earthing contact [h]	Rated operating voltage V [V]	Frequency [Hz]	Degree of protection [IP]
960623..	3	1	Other ratings	Other ratings	IP44 or IP44/IP54
		4	100 – 130	50 und 60	
		6*	200 – 250	50 und 60	
		7	480 – 500	50 und 60	
		9*	380 – 415	50 und 60	
12	Supply from an isolating transformer	50 und 60			
960624..	4	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 und 60	
		5	600 – 690	50 und 60	
		6*	380 – 415	50 und 60	
		7	480 – 500	50 und 60	
		9*	200 – 250	50 und 60	
		11	440 – 460	60	
12	Supply from an isolating transformer	50 und 60			
960625..	5	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 und 60	
		5	347/600 – 400/690	50 und 60	
		6*	200/346 – 240/415	50 und 60	
		7	277/480 – 288/500	50 und 60	
		9*	120/208 – 144/250	50 und 60	
		11	250/440 – 265/460	60	
12	Supply from an isolating transformer	50 und 60			

* Types with max 2 x socket outlet for household only available for clock position 6h or 9h.

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Type	Poles	Clock position earthing contact [h]	Rated operating voltage V [V]	Frequency [Hz]	Degree of protection [IP]
960723..	3	1	Other ratings	Other ratings	IP67 or IP66/IP67
		4	100 – 130	50 und 60	
		6*	200 – 250	50 und 60	
		7	480 – 500	50 und 60	
		9*	380 – 415	50 und 60	
12	Supply from an isolating transformer	50 und 60			
960724..	4	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 und 60	
		5	600 – 690	50 und 60	
		6*	380 – 415	50 und 60	
		7	480 – 500	50 und 60	
		9*	200 – 250	50 und 60	
		11	440 – 460	60	
12	Supply from an isolating transformer	50 und 60			
960725..	5	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 und 60	
		5	347/600 – 400/690	50 und 60	
		6*	200/346 – 240/415	50 und 60	
		7	277/480 – 288/500	50 und 60	
		9*	120/208 – 144/250	50 und 60	
		11	250/440 – 265/460	60	
12	Supply from an isolating transformer	50 und 60			

* Types with max 2 x socket outlet for household only available for clock position 6h or 9h.

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.