OVE Austrian Electrotechnical Association Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

OVE Certification Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 4



including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-236-03 Valid from: 2022 06 10 until: 2024 06 10

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

PC Electric Ges.m.b.H. Company: Diesseits 145 4973 St. Martin im Innkreis Austria

Product: Plug for industrial purposes

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 36445

Österreichischer Verband für Elektrotechnik Head of OVE Certification



T. Near Digitally signed by T. Neumayer CEmail=t.neumayer@ove.at Dipl.-Ing. T. Neumayer

Wien, 2022 04 07



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under https://akkreditierung-austria.gv.at.





Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Factory location(s):

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Plug for industrial purposes

Type designation: Rating:	Trademark:
027 Rated current: 32 A Insulation Voltage: 500 V 6P+E (not standardized) IP44 or IP44/IP54	PCE / ELCEE
8027 Rated current: 32 A Insulation Voltage: 500 V 6P+E (not standardized) IP44 or IP44/IP54	PCE / ELCEE
0272 Rated current: 32 A Insulation Voltage: 500 V 6P+E (not standardized) IP67 or IP66/IP67	PCE / ELCEE
80272 Rated current: 32 A Insulation Voltage: 500 V 6P+E (not standardized) IP67 or IP66/IP67	PCE / ELCEE

OVE Certification




Certificate No.: 43-236-03 Date: 2022 04 07 Page 2 of 4



Certificate No.: 43-236-03 Date: 2022 04 07 Page 3 of 4

Typecode



OVE Certification



Certificate No.: 43-236-03 Date: 2022 04 07 Page 4 of 4

Typelist

Туре	Rated current [A]	Earthing contact position [h]	Degree of protection	Rated operating voltage [V]	Frequency [Hz]
027 8027	32	1	IP44 or IP44/IP54	Other ratings	Other ratings
		2		> 50	> 300 - 500
		3		380 440	50 60
		4		100 - 130	50 and 60
		6		380 - 415	50 and 60
		7		480 - 500	50 and 60
		9		200 - 250	50 and 60
		10		> 50	> 100 - 300
		11		440 - 460	60
		12		Supply from an isolating transformer	50 and 60
0272 80272	32	1	IP67 or IP66/IP67	Other ratings	Other ratings
		2		> 50	> 300 - 500
		3		380 440	50 60
		4		100 - 130	50 and 60
		5		600 - 690	50 and 60
		6		380 - 415	50 and 60
		7		480 - 500	50 and 60
		9		200 - 250	50 and 60
		10		> 50	> 100 - 300
		11		440 - 460	60
		12		Supply from an isolating transformer	50 and 60

