OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

OVE CertificationKahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at





Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-245-04 Valid from: 2023 12 04

until: 2025 07 09

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: PC Electric Ges.m.b.H.

Diesseits 145

4973 St. Martin im Innkreis

Austria

Product: Rewirable portable socket outlet with side earthing contacts

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: TGM-VA EE 38188

Österreichischer Verband für Elektrotechnik

Head of OVE Certification


Digitally signed by T. Neumayer Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

OVE

Wien, 2023 12 13









Certificate No.: 43-245-04

Date: 2023 12 13 Page 2 of 3

Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Factory location(s):

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01

Product: Rewirable portable socket outlet with side earthing contacts

Type designation: Rating:	Trademark:
257 Rated voltage: AC 250 V Rated current: 16 A IP20 or IP54 see typecode	PCE





Certificate No.: 43-245-04

Date: 2023 12 13 Page 3 of 3

Typecode

